

Compatibility Statement of Battery

We

Company name: iPotisEdge Co., Ltd.
Postal address: No.299 Liangang Road, Suzhou New District, Suzhou, Jiangsu Province, 215129, China
Postcode: 215000
City Suzhou
Telephone number 86 15106135393
E-mail address li.jing@ipotisedge.com
Web: www.ipotisedge.com

declare that the DoC is issued under our sole responsibility and belongs to the following product:

Product: Rechargeable Li-ion Battery System
Model(s): Nora-C06-B06,Nora-C06-B12,Nora-C06-B18,Nora-C06-B24,Nora-B06
Description: (1) Nora-C06-B06: 307.2V, 20Ah, 6.144kWh;
 (2)Nora-C06-B12: 307.2V, 40Ah, 12.288kWh;
 (3) Nora-C06-B18: 307.2V,60Ah,18.432kWh;
 (4) Nora-C06-B24: 307.2V,80Ah, 24.576kWh;
 (5) Nora-B06: 307.2V, 20Ah, 6.144kWh;
 (6)Nora-C06-B30: 307.2V, 100Ah, 30.72kWh;
 (7) Nora-C06-B36: 307.2V,120Ah,36.864kWh;
 (8) Nora-C06-B42: 307.2V,140Ah, 43.008kWh;
 (9) Nora-C06-B48: 307.2V, 160Ah, 49.152kWh

Object of the statement described above is compatible with the inverters in the following table.

Inverter Manufacture	Product	Model
iPotisEdge Co., Ltd	Hybrid Inverter	IPT-5K-S, IPT-5K-SH, IPT-6K-S, IPT-6K-SH IPT-8K-S, IPT-8K-SH, IPT-10K-S, IPT-10K-SH
Senergy	Hybrid Inverter	SE 6KHB-D1/HV SE 5KHB-D1/HV SE 4K6HB-D1/HV SE 3K68HB-D1/HV SE 3K6HB-D1/HV SE 3KHB-D1/HV SE 6KHB-HV SE 5KHB-HV

		SE 4K6HB-HV SE 3K6HB-HV SE 3KHB-HV
--	--	--

Compliant to Best Practice Guide for Battery Storage Equipment Electrical Safety Requirements – version 1 – Pre-assembled battery system equipment/Preassembled integrated battery energy storage system equipment - Method 3 mandatory requirements

Singed for and on behalf of: iPotisEdge Co., Ltd.

Place of issue Date of issue Name Signature

Suzhou

2026.1.30

Lisa Jing

